

Message Text

UNCLASSIFIED

PAGE 01 KIGALI 00579 251226Z

ACTION SY-05

INFO OCT-01 AF-10 OC-06 ISO-00 SYE-00 CCO-00 FBOE-00

/022 W

-----048379 251227Z /10

P R 111420Z APR 78

FM AMEMBASSY KIGALI

TO SECSTATE WASHDC PRIORITY 6004

INFO AMEMBASSY ACCRA

AMEMBASSY NAIROBI

UNCLAS KIGALI 579

STATE FOR A/SY/NSU AND OC/PE

ACCRA FOR COMSPEC

NAIROBI FOR RCO;/RSS/O/C RTC

E.O. 11652C N/A

TAGS: ASEC, AFAC, NSU

SUBJECT: KIGAPRU RENOVATION: PRELIMINARY SEABEE INSPECTION

FOLLOWING ARE MORE IMPORTANT ITEMS OF INSPECTION. MORE
DETAILED REPORT WILL BE SENT LATER:

1. CONTRACTOR WOULD LIKE TO START WORK ON THE NEW
FLOOR AND EXTERIOR WALLS OF RM 6 THE WEEK OF 17 APRIL.
WILL THIS HAVE TO BE ACCOMPLISHED UNDER SEABEE/MSG
SURVEILLANCE?

2. SEABEES BELIEVE THE EXISTING EXTERIOR WALL WHICH IS
TO BE REMOVED SHOULD HAVE OPENING IN IT IN ACCORDANCE
WITH SEC B, PARA 2 OF GEN SPEC AS IT IS A LOAD-
BEARING WALL SUPPORTING THE CONC ROOF OVER C&R.

3. DOOR DV-1 (CALSS FIVE VAULT DOOR) WILL NOT HAVE ADEQUATE
UNCLASSIFIED

UNCLASSIFIED

PAGE 02 KIGALI 00579 251226Z

ROOM TO SWING IF INSTALLED IN PROPOSED POSITION. SUGGEST
LEAVING EXISTING WALL IN FOYER AREA AND INSTALLING DOOR AT
THIS POINT.

4. EXISTING WALL TO BE REMOVED IN ROOM 4 HAS A COLUMN AS AN
INTEGRAL PART. SEABEE NOT QUALIFIED TO SAY IF IT WOULD BE
SAFE TO REMOVE.

5. SEC C, PARA 5, SAYS WALLS ARE TO BE PAINTED CONC. DO NOT FEEL QUALITY OF FINISH WILL BE SATISFACTORY. REQUEST PERMISSION TO HAVE CONTRACTOR PLASTER THESE UNDER SEABEE SURVEILLANCE.

6. THE POWER SERVICE FROM COM POWER TO DISCONNECT SWITCH IN GEN ROOM IS ONLY A 63 AMP SERVICE, CABLE AND FUSES ONLY RATED FOR 63 AMPS.

7. FOLLOWING ITEMS NOT IN SEABEE BOM AND SHOULD BE PROCURED AND SHIPPED ASAP:

PCS 2-1/2 INCH SQ DUCT AA ONLY ONE ON HAND.

8. INCH KNIFE BLADE FUSES FOR MAIN DVISCONNECT -A NEED THREE AND RECOMMEND SIX SPARES.

1 ROLL NUMBER 2 AWG BLACK FOR GRND PULLS.

THE SUSPENDED CEILING AND LIGHTS ARE NOT ON POST YET.

CHILLER UNIT AND FAN COIL UNITS HAVE NOT ARRIVED YET. LESSER

UNCLASSIFIED

NNN

Message Attributes

Automatic Decaptioning: X
Capture Date: 01 jan 1994
Channel Indicators: n/a
Current Classification: UNCLASSIFIED
Concepts: n/a
Control Number: n/a
Copy: SINGLE
Draft Date: 11 apr 1978
Decaption Date: 01 jan 1960
Decaption Note:
Disposition Action: n/a
Disposition Approved on Date:
Disposition Case Number: n/a
Disposition Comment:
Disposition Date: 01 jan 1960
Disposition Event:
Disposition History: n/a
Disposition Reason:
Disposition Remarks:
Document Number: 1978KIGALI00579
Document Source: CORE
Document Unique ID: 00
Drafter: n/a
Enclosure: n/a
Executive Order: N/A
Errors: N/A
Expiration:
Film Number: D780176-0318
Format: TEL
From: KIGALI
Handling Restrictions: n/a
Image Path:
ISecure: 1
Legacy Key: link1978/newtext/t19780468/aaaacfbk.tel
Line Count: 84
Litigation Code IDs:
Litigation Codes:
Litigation History:
Locator: TEXT ON-LINE, ON MICROFILM
Message ID: 958e61b2-c288-dd11-92da-001cc4696bcc
Office: ACTION SY
Original Classification: UNCLASSIFIED
Original Handling Restrictions: n/a
Original Previous Classification: n/a
Original Previous Handling Restrictions: n/a
Page Count: 2
Previous Channel Indicators: n/a
Previous Classification: n/a
Previous Handling Restrictions: n/a
Reference: n/a
Retention: 0
Review Action: RELEASED, APPROVED
Review Content Flags:
Review Date: 18 apr 2005
Review Event:
Review Exemptions: n/a
Review Media Identifier:
Review Release Date: n/a
Review Release Event: n/a
Review Transfer Date:
Review Withdrawn Fields: n/a
SAS ID: 3000245
Secure: OPEN
Status: NATIVE
Subject: KIGAPRU RENOVATION: PRELIMINARY SEABEE INSPECTION FOLLOWING ARE MORE IMPORTANT ITEMS OF INSPECTION. MORE DETAILED REPORT WILL BE SENT LATER
TAGS: ASEC, AFAC, NSU
To: STATE
Type: TE
vdkgvkey: odbk://SAS/SAS.dbo.SAS_Docs/958e61b2-c288-dd11-92da-001cc4696bcc
Review Markings:
Sheryl P. Walter
Declassified/Released
US Department of State
EO Systematic Review
20 Mar 2014
Markings: Sheryl P. Walter Declassified/Released US Department of State EO Systematic Review 20 Mar 2014